



ऊर्जा दक्षता ब्यूरो  
(भारत सरकार, विद्युत मंत्रालय)  
**BUREAU OF ENERGY EFFICIENCY**  
(Government of India, Ministry of Power)



BEE/S&L/Chillers/40/2023-24

1<sup>st</sup> May, 2024

**ADVISORY**

चिल्लर के सभी निर्माताओं और परमिटियों को महत्वपूर्ण निर्देश

**Important instructions to all Manufactures & Permittees of Chiller**

1. This is with reference to the Standards and Labeling (S&L) Program for Chiller under mandatory phase. The notifications for Chillers have been published in Gazette of India vide S.O. 4088 (E) and S.O. 4089 (E).
2. In the above stated S.O. 4088 (E) and S.O. 4089(E), the rated voltage for three phase power supply '400V' should be read as '415V' as per IS standard 16590:2023, wherever it stated.

**परमिटियों से अनुरोध है कि वे इस परामर्श के संबंध में आवश्यक अनुपालन करें।**

*Permittees are requested to make necessary compliance with regards to this advisory.*

प्र. सामल

(प्रभातनलिनी सामल)

निदेशक